

# Tratament chimic: CALORIFERE RUGINITE, PARTIAL RECI CALORIFERE OTEL/FONTA , INSTALATII SANITARE, TEAVA NEAGRA,

Probleme tratate: RUGINA, CALCAR, NAMOL

Materiale: OTEL / FONTA



CHIMIA  
INSTALATIEI  
TERMICE

## CHECK SERVICE




Verificare parametrilor fluid

## CLEANEX RAD PLUS



Solutie 20-30%  
(cca 20kg / 100l apa)



Recirculare: 20-30 min fiecare  
circuit/calorifer (poate fi recirculata  
si in sistem functional 2-3 zile)




Monitorizare: pH<5

## NEUTRALYZER ALCALIN



Solutie 1-4%  
(cca 1-2kg / 100l apa )



Recirculare: 5-10 min  
(fiecare circuit/calorifer)

## APA DEMINERALIZATA



Clatire instalatie pana la pH 6.5-7.5  
Incarcare cu apa demineralizata

## INSTAL PROTECT



Dozare 1-2%  
(cca. 1kg / 100l)